**AWTA PRODUCT TESTING** 

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

Client : Homemirus Pty Ltd 4 Naughton Street			Test Number 14-000895   Issue Date 27/11/201			
	Greenacre N	ISW 2190		Print Date	:	27/11/2014
Sample D	escription	Clients Ref :	"Kronoswiss Laminate 12mm"			
Engineered flo			oring			

Sample Description	
	Engineered flooring
	Colour : Natural
	End Use : Flooring
	Nominal Composition : HDF
	Nominal Mass per Unit Area/Density : 830kg/m3
	Nominal Thickness : 12mm

## AS/ISO 9239.1-2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a **Radiant Heat Source**

Date of Sample Arrival		06/10/2	014		
Date Tested 19/11/2014					
CHF Value	1	2	3	Mean	
Length	7.2	7.4	7.4	7.3	kW/m²
Width	8.2	-	-	-	kW/m²
Smoke Value	1	2	3	Mean	
Length	6	4	4	5	%.min
Width	4	-	-	-	%.min
Penetration of flame through to substrate Yes					
Smouldering Yes					

9195

1047

Australian Wool testing Authority Ltd Copyright - All Rights Reserved C



Accredited for compliance with ISO/IEC 17025 - Chemical Testing - Mechanical Testing Performance & Approvals Testing

relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Accreditation No Accreditation No : Accreditation No.

1.5

Page 1 of 2

983

985

1356



HAFL A. JACKSON B.Sc.(Hons)

APPROVED SIGNATORY

0204/11/06



Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

Client :	Homemirus Pty Ltd
	4 Naughton Street
	Greenacre NSW 2190

Test Number	:	14-000895
Issue Date	:	27/11/2014
Print Date	:	27/11/2014

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2001 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was clamped to a substrate of 6mm thick fibre reinforced cement board prior to testing.

9195

1047

C Australian Wool testing Authority Ltd Copyright - All Rights Reserved




Accredited for compliance with ISO/IEC 17025 - Chemical Testing - Mechanical Testing - Performance & Approvals Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

: Accreditation No. : Accreditation No. : Accreditation No.

983 985 1356





APPROVED SIGNATORY